

**DRINKING WATER AND SANITARY CONDITION CERTIFICATE**


**No. DLWQTML/UJS/2025-26/03-06**

**Dated: 10/03/2026**

It is certified that an inspection team headed by **Dr. Vikash Kandari, Technical Manager** (Name of Officers with designation) from **District Level Water Quality Testing and Monitoring Laboratory, UJS, Dehradun** inspected the school **Mount Litera Zee School, 9-A Rishi Vihar Shimla Bye pass Road, Mehuwala, Dehradun, Uttarakhand, on 07.03.2026**, and on the basis of Water Test Report (Attached) bearing **DLWQTML/UJS/2025-26/03-06 dated 10/03/2026 of District Level Water Quality Testing and Monitoring Laboratory, Uttarakhand Jal Sansthan**, certified that the school **Mount Litera Zee School, Dehradun** has safe drinking water facilities for the students and members of staff of the institution. School also maintains hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

**This Certificate is valid till for 06 Month**

Signature with Seal:



Name: (Dr. Vikash Kandari)

Designation: Technical Manager

Name & Address of the Office / Department:

To,

**Mount Litera Zee School,**  
**9-A Rishi Vihar Shimla Bye pass Road,**  
**Mehuwala, Dehradun, Uttarakhand.,**

**Technical Manager**  
**DLWQTML**  
**Uttarakhand Jal Sansthan**  
**Dehradun**



**District Level Water Quality Testing and Monitoring Laboratory  
Uttarakhand Jal Sansthan, 32, Rajpur Road, Dehradun**

**TEST REPORT**

<b>Name and Address of Organization/ Customer</b>	Mount Litera Zee School, 9-A Rishi Vihar Shimla Bye Pass Road Mehuwala, Dehradun, Uttarakhand.		
<b>Reference Sample Identification:</b>	DLWQTML/UJS/2025-26/03-06	<b>Reporting Date</b>	10/03/2026
<b>Product Description</b>	Drinking Water	<b>Sample Location</b>	(Borewell) 9-A Rishi Vihar Shimla Bye Pass Road Mehuwala, Dehradun.
<b>Date and Time of Sample Received:</b>	07/03/26 & 1:40 PM	<b>Sample Collected by</b>	Customer
		<b>Duration of Analysis</b>	07/03/2026 to 09/03/2026

SN	Water Quality Parameters Under Chemical Scope	Results	Acceptable Limit (IS10500:2012)	Permissible Limit (IS10500:2012) in the Absence of alternative source	Std. Test/Method	Conformity Statement
1.	pH at 25°C	7.68	6.5 to 8.5	No Relaxation	IS 3025 (Part 11)	Pass
2.	Total Dissolved Solids (TDS), mg/L	280	500 Max	2000 Max	IS 3025 (Part 16),	Pass
3.	Turbidity, NTU	0.88	1 Max	5 Max	IS 3025 (Part 10),	Pass
4.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5)	Pass
5.	Colour, CU	Less than 01	5 Max	15 Max	IS 3025 (Part 4)	Pass
6.	Total Alkalinity (as CaCO <sub>3</sub> ), mg/L	160	200 Max	600 Max	IS 3025 (Part 23),	Pass
7.	Total Hardness (as CaCO <sub>3</sub> ), mg/L	200	200 Max	600 Max	IS 3025 (Part 21),	Pass
8.	Calcium as Ca, mg/l	33.6	75 Max	200 Max	IS 3025 (Part 40),	Pass
9.	Chloride, mg/L,	28	250 Max	1000 Max	IS 3025 (Part 32):	Pass
10.	Magnesium as Mg, mg/l	28.18	30 Max	100 Max	APHA 23 <sup>rd</sup> -3500-Mg Method B:	Pass
11.	Fluoride, mg/L	Less than 0.2	1.0 Max	1.5 Max	IS 3025 (Part60/Sec 1)	Pass
12.	Nitrate, mg/L	1.64	45 Max	No Relaxation	IS 3025 (Part34/Sec 1)	Pass
13.	Sulfate, mg/L	40	200 Max	400 Max	IS 3025 (Part24/Sec 1)	Pass
14.	Total Coliform, (in 100ml)	Absent	Shall not be detectable in any 100 ml sample		IS 15185:2016	Pass
15.	E. coli, (in 100ml)	Absent	Shall not be detectable in any 100 ml sample		IS 15185:2016	Pass

**Note:-**

1. The results listed refer only to tested sample and applicable parameters 2. This certificate is not be reproduced wholly or in parts promotional publicity or legal purpose without permission of authority of testing laboratory. 3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer. 4. The results apply to the sample as received 5. The Laboratory is responsible for all the information provided in the report, except when information is provided by the customer

\*\*\*\* End of Report\*\*\*\*

Review and Authorized By  
  
(Dr. Vikash Kandari)  
Technical Manager, Lab

**Technical Manager**  
**DLWQTML**  
**Uttarakhand Jal Sansthan**  
**Dehradun**